SAFE DRINKING WATER AND SANITARY CONDITION CERTIFICATE

No. 02/26 Dated. 12/02/26

It is certified that an inspection team headed by... RAJEEV YADAV (SFI)...

(Name of Officers with designation) from N.P.P. Kosikalan..... PHED

inspected the. S.D. Public School Brijwasi Road Nandgaon (Mathura)

(Name & Address of the school) on..12/02/26.... (date of inspection)and on the basis of

Water Test Report (Attached) bearing no...MTA/26/CL/02/0000657 dated....18/02/26

of.....District Water testing laboratory.....(PHED Lab)certified

thatthe.....S.D. Public School.....(Name of school) has safe drinking

waterfacilities for the students and members of staff of the institution. School is also maintains the hygienic sanitation condition in the school building & the campus as per norms prescribed by the Central/State/ U.T. Govt.

This certificate is valid till...11/02/27

Signature with Seal:.....

Name. RAJEEV YADAV

Designation..... सफाई एवं खाद्य निरीक्षक

Name & Address of the Office / Department:..... म०पा०प० कोसीकलाँ (मथुरा)

(An NABL Accrediated Lab)

District Water Testing Laboratory

Water Works Compound, Asha Nagar, Jai Singhpura, Gayatri Tapobhoomi, Mathura.

TC-10347

Water Test Report

Report No:	MTR/26/CL/02/00006577	Issue Date	18-02-2026	Lab	T-6437
Remark:	This sample has been collected and submitted to the lab by the customer himself and All information related to the sample, such as customer details and basic details of the sample has been filled in as per customer's instructions.This report is not responsible for any location or source conditions. This Report is only intended to provide a testing report of the submitted sample and does not claim or take responsibility for any location or source.			Pages	1/1

Customer Details

Contact Person	Mr. Karan Singh	Address	Brijwari Road, Nandgaon, Mathura-2131312
Office Name and Address	NA		
Reference Letter No.	SDPS/2026	Date.	16/02/2026

Basic details of sample

District	Mathura	Block /Area	Nandgaon
Gram Panchayat	Nandgaon	Village	Nandgaon
Habitation	S D PUBLIC SCHOOL, NANDGAON	Location	Brijwari Road, Nandgaon, Mathura-2131312
Water Source	RO Water	Sample No.	01-577
Quantity of Sample	1 L	Sample Collection Date	16-02-2026
Receiving Date	16-02-2026	Sample Collector (Site)	Mr. Karan Singh
Sample Depositor (at Lab)	Mr. Karan Singh	Sampling Method	-
Analysis Start Date	16-02-2026	Analysis Complete Date	17-02-2026
Temperature	27.3 °C	Humidity	59%

Technical data of Analysis

S.No	Analyzed parameters	Mesurment Unit	Observed Value	Specified Values as per BIS 10500 (2012)		Ref. Method of Analysis (APHA 24th Edition : 2023)
				Requirement (Acceptable Limit)	Permissible Limit (Absence of Alternate Source)	
1	2	3	4	5	6	7
1	pH @ 25 °C	-	7.16	6.5-8.5	6.5-8.5	4500-H+ Method B
2	Turbidity	NTU	2.53	2.50	5.00	2130- Turbidity Method B
3	TDS	mg/L	130	500	2000	2540-TDS Method C- (Dried at 180° C)
4	Fluoride as Fl	mg/L	NIL	1.00	1.50	4500-F Method C- (Electrode method)
5	Chloride as Cl	mg/L	45	250	1000	4500-Cl Method B- (Argentometric method)
6	Total Hardness	mg/L	40	200	600	2340-T.H Method C- (EDTA Titrimetric)
7	Total Alkalinity	mg/L	36	200	600	2320- Alkalinity Method B- (Titration)
8	Calcium as Ca	mg/L	-	75	200	3500-Ca Method B- (EDTA method)
9	Magnesium as Mg	mg/L	-	30	100	3500-Mg Method B- (By Calculation)
10	Iron as Fe	mg/L	NIL	1	No Relaxation	3500-Fe Method B (Phenanthroline Method)
11	Nitrate as NO_3	mg/L	NIL	45	No Relaxation	4500- NO3 Method D (UV Screening Method)
12	Sulphate as SO_4	mg/L	11	200	400	4500-SO4 Method E (Turbidimetric Method)
13	Color	Hazen	6	5	15	Color 2120 B (Visual Comparison Method)
14	Taste	-	Agreeable	Agreeable	Agreeable	IS 3025 (Part 7-8):2019
15	Odour	-	Agreeable	Agreeable	Agreeable	IS 3025 (Part 5):2018

B.D.L- Below Detection limit, N.T- Not Tested

Note

1. This Certificate refers only to the particular sample submitted for testing.
2. This certificate shall not be reproduced, except in full, unless written permission for the publication of an approved abstract has been obtained from Head of Laboratory.
3. The test results reported in this certificate are valid at the time of and under the stated conditions of measurements.
4. Sample will be stored up to 07 days (in case of non-perishable items only) from the date of issue of tests reports
5. The **Bold and Underline** observed value is a type of notation for outlier or out of the Acceptable and Permissible Limit.
6. After taken the report please give us short feedback by rating 1 to 5 star according our services

Review on Analysis

1. Only basis of above parameter analysis data values for given sample within safe range and under Acceptable Limit according to BIS 10500:2012.

· PASS (✓) · FAIL ( ) potable for drinking purpose on CL rehtarly.

Authorized Signatory
(Chemist/Quality/Technical Manager)
District Water Testing Laboratory, Mathura

labmathurajalnigam@gmail.com

**********End of Report**********